



*Principal*  
**THE CRESCENT SCHOOL**  
Azad Nagar, Rahmat Nagar  
Burnpur-713325

*Md. Samir Khatun*  
**Secretary / Treasurer**  
**THE CRESCENT SCHOOL**  
RAHMATNAGAR, AZAD NAGAR  
BURNPUR-713325 (W.E.)

**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, Paschim Bardhaman**  
**West Bengal Fire & Emergency Services**  
**Bhangakhuti, Purba Burdwan, P.O.:- Rajbati, Pin :- 713104**

Memo no.:IND/WB/FES/20192020/85243

Date: 09-05-2023

**From:**  
**Divisional Fire Officer, Paschim Bardhaman**  
**West Bengal Fire & Emergency Services**

**To: The Crescent School,**  
**Mouza - Ismile, Plot no. 824, 841, Kh no. 431, Jl no. 22, ward no. 83, under A. M.C, Azad Nagar, Rahmatnagar,**  
**Burnpur, Ps. Hirapur, Dist. Paschim Bardhaman, Pin 713325.**

**Sub: Renewal of Fire safety certificate in the name & style CRESCENT SCHOOL of an existing Construction G+2 storied Educational Building at the premises AT AZAD NAGAR, RAHMATNAGAR, BURNPUR, PLOT NO. 824, 841, KH NO. 431, JL NO. 22, MOUZA- ISMILE, PS- HIRAPUR UNDER AMC, WARD NO. 38, PASCHIM BARDHAMAN. PIN 713325.**

This is in reference to your application no. 0125191239100169 dated 31-03-2023 regarding the Renewal of Fire safety certificate in the name & style CRESCENT SCHOOL of an existing Construction G+2 storied Educational Building at the premises AT AZAD NAGAR, RAHMATNAGAR, BURNPUR, PLOT NO. 824, 841, KH NO. 431, JL NO. 22, MOUZA- ISMILE, PS- HIRAPUR UNDER AMC, WARD NO. 38, PASCHIM BARDHAMAN. PIN 713325.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

1. Driveway must be free of any type of obstruction for EASY movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.

5. A fire control room including a closed circuit T.V. system will have to be installed which observes entire of the buildings.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable of the Building.
7. Good hose keeping of the all building shall be provided .
8. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
9. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
10. Transformer and Dg set shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.
11. A crew of trained Fireman under an experience officer shall be maintained round the clock for safety of the building.
12. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
13. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
14. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
15. Periodical flashing of water in the Hydrants shall be made to maintain the efficiency working performance of above mention system.
16. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.
17. Fire license to be obtained from the License Department of W.B.F&E.S for storing combustibile materials.
18. All the electrical cable should be paint by fire stop paint to check the spread of fire.
19. If anything happens for improper life safety measure in the building within this period then authority will be responsible for that.
20. The renewal of fire safety certificate is valid for three years from the date of issue, and has to be renewed after Three years certifying about the satisfactory services, performance of all the Life And Fire Safety arrangements installations of the building.

Signature valid

Digitally signed by SHYAM  
CHANDRA MOUDAL  
Date: 2023.05.09 18:20:06 IST

Divisional Fire Officer, Paschim Bardhaman  
West Bengal Fire & Emergency Services

  
**Principal**  
**THE CRESCENT SCHOOL**  
Azad Nagar, Rahmat Nagar  
Burnpur-713325

  
**Secretary / Treasurer**  
**THE CRESCENT SCHOOL**  
**RAHMATNAGAR, AZAD NAGAR**  
**BURNPUR-713325 (W.B.)**